

ANNOTATION

This project considers the calculation of the 30th stage of the turbine PT-65 / 75-130 / 13 as a result of which the turbine is transferred to the operating mode with an impaired vacuum. This makes it possible to increase the overall economic efficiency of the turbine itself by completely eliminating heat losses with circulating water in the condenser.